

LP	ROZDZIELNICA	IŁOŚĆ BOKSÓW	Pi [kW]	Kz	Ps [kW]	Pp [kW]	cos fi	Qz [kVAr]	Sz [kVA]	IŁOŚĆ FAZ	Iobc [A]	Izab w RG [A]	Izab w ZŁĄCZU [A]
1	Targowisko												
1.1	SZAFKA ZŁĄCZOWO-POMIAR. 1 W.L.Z. box otwarty RbB	39	4,0	1	4,0	4,0	0,93	1,6	4,3	1	18,7	20	
	SZAFKA ZŁĄCZOWO-POMIAR. 1	39	159,9	0,2	39,0	156,0	0,93	15,4	42,0	3	60,6		100
2	SZAFKA ZŁĄCZOWO-POMIAR. 2												
2.1	W.L.Z. box zamknięty RbA	15	12,0	1	12,0	12,0	0,93	4,7	12,9	3	18,6	20	
2.2	W.L.Z. administracja Ra	1	20,0	1	20,0	20,0	0,93	7,9	21,5	3	31,1	32	
	SZAFKA ZŁĄCZOWO-POMIAR. 2	15	215,5	0,3	60,8	200,0	0,93	24,0	65,4	3	94,5		125
	ZŁĄCZE KABLOWE ZK-4		375,4	0,3	99,8	356,0	0,93	39,5	107,3	3	155,1		200